

Identification of Achievable Performance Standards
Source Category: Large Water Heaters and Small Boilers
(75,000 Btu/hour up to and including 2 million Btu/hour)

Regulated Component	Pollutant	Rule/Measure/Date							
		South Coast 1146.2, Emissions of Oxides of Nitrogen from Large Water Heaters and Small Boilers Adopted 1/9/98							
		Performance Standard							
Large Water Heaters and Small Boilers	NOx	30 ppm @ 3% oxygen on a dry basis for units with rated heat input greater than 400,000 Btu/hour up to and including 2 million Btu/hr							
		x 50 ppm @ 3% oxygen on a dry basis for units with rated heat input from 75,000 Btu/hr up to and including 400,000 Btu/hr and manufactured on or after 1/1/2000							
	CO	40 ppm							

S:\DRAT\WEBDOCS\LWAT1.WP6